

## Lift and Escalator Industry Association

33-34 Devonshire Street London W1G 6PY Tel: 020 7935 3013 Fax: 020 7935 3321

E-mail: leia.enquiries@virginnet.co.uk Website: www.leia.co.uk

To: All Members

24 November 2000

Dear Member

## SAFETY WARNING NOTICE

We have received the enclosed information which Cable Lift Installations Ltd have asked be circulated to all members.

I trust the content is self-explanatory, please be guided accordingly.

Yours faithfully

D M Fazakerley Managing Director


EMTA Awards Limited

**Approved Assessment Centre** 









## **Cable Lifts**

Cable Lift Installations Ltd.

50 Brooksbys Walk, Hackney,

London E9 6DA

Tel: 020 8986 9416 Fax: 020 8986 0229

E-mail: cable@cablelift.co.uk

Lift & Escalator Industry Association 33/34 Devonshire Street London W1N 1RF

Attn: Mr. David Fazakerley



21 November 2000

Dear Mr. Fazakerley,

Re: Safety Warning notice.

As previous suppliers of ORONA equipment Cable Lift Installations Ltd advise that we have been sent updated installation instructions (version 4) for the ORONA PA-V3F Door Operator.

We draw your attention to the following extract from the installation instructions.

## SAFETY WARNING

When the inverter is on, the motor gets electrically charged and, if touched, it causes electrical shock. To prevent the worker from electrical shocks, the motor is covered in casing. Avoid touching the motor and do not remove the cover until the mains power supply has been disconnected from the inverter.

It should be noted that all parts of the motor are live unless isolated at the point of connection, which is within the control panel. Should you require any further information in the first instance, you may contact Mr D Scrivener at Cable Lift Installations Ltd. Tel. 020 8986 9416.

Could you please distribute this to association members as appropriate.

Yours sincerely,

**David Scrivener** 

Director & General Manager



