



**Lift and Escalator Industry Association**

33-34 Devonshire Street London W1G 6PY  
Tel: 020 7935 3013 Fax: 020 7935 3321

E-mail: leia.enquiries@virginnet.co.uk  
Website: www.leia.co.uk

9<sup>th</sup> July 2001

To: All Members  
cc: The Quality and Technical Committee (Code No. 435)

Dear Sir/Madam,

**HAMMOND & CHAMPNESS : TYPE 42 HOME LIFT**

Please find enclosed safety bulletin from Thyssen Lifts & Escalators in connection with any H&C Type 42 Homelift that has not yet undergone appropriate modification to the safety gear.

Accordingly, members are urged to notify Thyssen Lifts of any H&C Type 42 Homelift that they currently maintain.

Yours faithfully


Robert N Lee  
Director, Technical Services



EMTA Awards Limited  
Approved Assessment Centre



*A company limited by guarantee.*  
Registered in England N° 3851206. Registered office as above.



Certificate N° 42056109



## Notification to LEIA Members

### Re: Hammond & Champness Type 42 Home Lifts


Following a recent incident it has come to our attention that a safety gear modification that should have been carried out by H&C some time ago on all H&C Type 42 Homelifts had not been fitted.

In the interest of safety we would like to check these lifts to ensure the modifications have been carried out on all lifts. We would ask all members to advise us of any H&C Type 42 Homelifts they currently maintain and Thyssen will arrange to check the safety gear and modify should it be required.

To allow members to easily identify the H&C Type 42 Homelift the attached sketch shows the unique arrangement of these lifts.

Please contact Mr John Sains at our Potter Bar Office

Telephone 01707672067



LIFT WELL PLAN  
( Lowest level )

H+C - 42 HOME LIFT